

JACKSON TOWNSHIP

APPLICATION FOR PERMIT TO DRILL POTABLE WELL

APPLICATION NO. _____

Application must be completed, fee paid and permit received before drilling operations begin.

In accordance with the provisions of the Jackson Township Well Ordinance Number 147-04, a permit to drill a potable water well is hereby requested.

Well Site Address:

Well Site:

Tax Map _____ Parcel No. _____

Property Owner's Name and Address:

Well Driller's Name and Address:

For Office
Use Only

APPLICANT MUST PROVIDE A PLAN WITH THIS APPLICATION SHOWING THE LOCATION OF ALL EXISTING OR PROPOSED WELLS, APPLICABLE SETBACK DISTANCES FOR WELLS, AND EXISTING OR PROPOSED SEWAGE DISPOSAL DRAIN FIELDS AND SEPTIC TANKS ON THE LANDS OF APPLICANT AND ON ANY IMMEDIATELY ADJOINING LANDS.

AS PART OF THIS APPLICATION PROCESS, THE OWNER AGREES TO ABIDE BY THE FOLLOWING CONDITIONS:

- A. Owner will notify the Commonwealth of Pennsylvania licensed well driller that the well driller's operations and installation must be in accordance with the standards and regulations under the terms of the Jackson Township Well Ordinance.
- B. In the event that this well or any existing well on said property, is abandoned, the owner will assume the responsibility for plugging or sealing the well in accordance with the Jackson Township Well Ordinance
- C. Well Driller's Report Form, as required by the Pennsylvania Department of Environmental Protection and certification from the well driller that the well construction has complied with the requirements and standards of the Jackson Township Well Ordinance must be provided to the Township.
- D. At a minimum, the sample of water produced from this well shall be subjected to an examination by Pennsylvania Department of Environmental Protection certified water laboratory for the presence of the following contaminants and certified to be potable. A copy of such analysis and certification must be

PERMIT TO DRILL POTABLE WELL

1. Total coliforms - total plate counts total coliform/100 milliliters
2. pH
3. Nitrates
4. Sulfates
5. Iron
6. Manganese
7. Lead
8. Chlorides
9. Where the Township believes there may be contaminations from other pollutants, additional testing may be required, including, but not limited to:
 - a. TCE, PCE, and trichlorethane
 - b. Benzene, toluene & xylene
 - c. Detergents (MBAS)

NOTE: The issuance of a Well Permit and a Certificate of Compliance therewith shall not be construed as a guarantee that the system will function satisfactorily. No responsibility or liability for the construction of any well and any amount of potable water supply shall be deemed to be placed upon Jackson Township or its officers, agents, or employees by virtue of the terms of this Permit or otherwise.

I hereby certify that all of the above statements and the statements contained in any papers or plans submitted herewith are true and correct to the best of my knowledge and belief:

Application Date: _____

Applicant's Signature: _____

Applicant's Address: _____

Applicant's Telephone Number: (_____) _____

Area Code Home Telephone Number Work Telephone Number

FOR OFFICE USE ONLY

INSPECTIONS

Site/Location Inspection Made On: _____ By: _____

Well Location: Distance Set backs:

- | | |
|---|---|
| _____ Approved On-Lot Sewage Disposal System (Min. 100') | _____ Existing Septic Tank, Distribution Box (Min. 50') |
| _____ Distance from adjacent lot septic system drain field or absorption area (Min. 100') | _____ From agricultural field (Min. 50') If Not _____' |
| _____ Lakes, ponds, streams, other water surfaces (Min 25') | _____ Storm drains, storm water detention ponds (Min. 25') |
| _____ Prep area or storage of hazardous spray materials, fertilizers or chemicals, salt piles (Min. 300') | _____ Sewer lines and drains carrying waste (except concrete encased or ductile iron pipe (50') |
| _____ Sewage seepage pits, cesspools (Min. 100') | _____ Farm Silos, Barnyards (Min. 100') |
| _____ Rainwater pits (Min. 25') | _____ Spray irrigation site, sewage sludge and septic disposal sites (Min. 300') |
| _____ Property Lines or right-of-way (Min. 10') | _____ Bldg foundations (except bldgs enclosing just water well and/or water well pumps (Min. 30') |
| _____ Dedicated road right-a-way (Min. 15') | |
| _____ Any other potential source of pollution each case would need distance approved | |

Construction Permit No. _____ Date Issued _____ Issued By: _____